

Emission Test Certificate

Friday, December 30th, 2022


Supplier VIROSEAL Pty Ltd (2/23 Garden Drive, Willawong, QLD, 4110, Australia).
Product Name VIROSEAL Sealer
Product Description Polyurethane/Acrylic Clear Dispersion Sealer.
Date Tested 22nd December 2022 (Tested through Foray Laboratory – NATA Accreditation 1231)
Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours)

<p align="center">Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">VIROSEAL Sealer</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$</p>	<p align="center">Total Volatile Organic Compound Emission Rate: $0.092 \text{ mg/m}^2/\text{hr}$</p>
<p align="center">Formaldehyde Emission Rate Limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$</p>	<p align="center">Formaldehyde Emission Rate: $0.019 \text{ mg/m}^2/\text{hr}$</p>



Dr. Vyt Garnys
 Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant



Dr. Tuan Duong
 Ph.D., B.Eng. (Chemical)
 Senior Consultant

Issued Date: 30/12/2022

Expired Date: 30/12/2027

P22120047

VOC Content Test Certificate

Wednesday, 16 November 2022

Supplier VIROSEAL Pty Ltd (2/23 Garden Drive, Willawong, QLD, 4110, Australia)


Sample Description VIROSEAL Sealer – Polyurethane/Acrylic Clear Dispersion Sealer.

Date Tested 14 November 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from the Green Building Council of Australia.

Test Data


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	VIROSEAL
Primer, Sealers, and Prep Coats Limit: 65 grams per liter	13 grams per litre as VOC content per material
Meets GBCA VOC Content Requirement	Yes



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BE (Chem. Eng.)
 Senior Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant

Date of issue: 16/11/2022.

Date of Expiry: 16/11/2027.

P22110046